

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7150-1591:111 Page 1 of 1

CATEGORY: Boxes/Pull Stations

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

DESIGN: Models 270, 270P, 270-SPO, 270A-SPO, 270-DPO, 270A-DPO, 270-DOC, 276B, 277B, 278B, 279B, 279TC, 279P, 279T, 279L, 276A-REL, 278A-REL, 5966B, 5966BR, 5966BV, 5966BRV, 6296B-270, 6296B-K279, 6296B-T279, 8557-B301, 8557-B311, 8558-B301, 8558-B311 and 8558-B312 manual pull stations. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as non-coded fire alarm pull stations for use with separately listed compatible fire alarm control units.

NOTE:

1. Models provided with two-wire lead and normally closed switch contacts are not approved for fire alarm signaling use.
2. Formerly 7150-0073:117 and 7150-1388:121

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager